



## JACKSON COUNTY UTILITY AUTHORITY

*Serving the People...Protecting the Environment*

### Directors

Kevin Coggin • Jackson County

Thomas Eldridge • Jackson County

Andrew J. Elly • Moss Point

Kevin Miller • Jackson County

Michael R. Murphy • Pascagoula

Jerry Munro • Ocean Springs

Marshall Smith • Gautier

# 2017 Consumer Confidence Report SAWS - System 0300033 Supplement

## Other Information

Please note that any customer being served by Saint Andrews Water and Sewer May 23, 2017 your water source and system identification is changed on May 24, 2017. Your new water supply and system is JCUA - West PWSID 0300164. You should consider the information in this supplement for your water supply from January 1, 2017 through May 23, 2017 and the information in the main body of this report for your water supply after May 23, 2017.

---

## Water Quality Data Table

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of contaminants in water provided by public water systems. The table below lists all of the drinking water contaminants that we detected during the calendar year of this report. Although many more contaminants were tested, only those substances listed below were found in your water. All sources of drinking water contain some naturally occurring contaminants. At low levels, these substances are generally not harmful in our drinking water. Removing all contaminants would be extremely expensive, and in most cases, would not provide increased protection of public health. A few naturally occurring minerals may actually improve the taste of drinking water and have nutritional value at low levels. Unless otherwise noted, the data presented in this table is from testing done in the calendar year of the report. The EPA or the State requires us to monitor for certain contaminants less than once per year because the

---

1225 Jackson Avenue, Pascagoula, Mississippi 39567 • Phone: (228) 266-2225 • Fax: (228) 762-3299 • [www.jcua-ms.us](http://www.jcua-ms.us)

AN EQUAL OPPORTUNITY EMPLOYER AND UTILITY PROVIDER

concentrations of these contaminants do not vary significantly from year to year, or the system is not considered vulnerable to this type of contamination. As such, some of our data, though representative, may be more than one year old. In this table you will find terms and abbreviations that might not be familiar to you. To help you better understand these terms, we have provided the definitions below the table.

Contaminants	MCLG or MRDLG	MCL, TT, or MRDL	Detect In Your Water	Range		Sample Date	Violation	Typical Source
				Low	High			
<b>Disinfectants &amp; Disinfection By-Products</b>								
(There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants)								
Chlorine (as Cl <sub>2</sub> ) (ppm)	4	4	1.56	.32	3.8	2017	No	Water additive used to control microbes
Haloacetic Acids (HAA5) (ppb)	NA	60	27	NA	NA	2017	No	By-product of drinking water chlorination
TTHMs [Total Trihalomethanes] (ppb)	NA	80	59.1	NA	NA	2017	No	By-product of drinking water disinfection
<b>Inorganic Contaminants</b>								
Barium (ppm)	2	2	.0066	.0049	.0066	2015	No	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits
Chromium (ppb)	100	100	2.3	2.3	2.3	2015	No	Discharge from steel and pulp mills; Erosion of natural deposits

Contaminants	MCLG or MRDLG	MCL, TT, or MRDL	Detect In Your Water	Range		Sample Date	Violation	Typical Source
				Low	High			
Fluoride (ppm)	4	4	.461	.437	.461	2015	No	Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories
Selenium (ppb)	50	50	2.5	2.5	2.5	2015	No	Discharge from petroleum and metal refineries; Erosion of natural deposits; Discharge from mines
Contaminants	MCLG	AL	Your Water	Sample Date	# Samples Exceeding AL	Exceeds AL	Typical Source	
<b>Inorganic Contaminants</b>								
Copper - action level at consumer taps (ppm)	1.3	1.3	.1	2015	0	No	Corrosion of household plumbing systems; Erosion of natural deposits	
<b>Inorganic Contaminants</b>								
Lead - action level at consumer taps (ppb)	0	15	4	2015	0	No	Corrosion of household plumbing systems; Erosion of natural deposits	

Unit Descriptions	
Term	Definition
ppm	ppm: parts per million, or milligrams per liter (mg/L)
ppb	ppb: parts per billion, or micrograms per liter (µg/L)
NA	NA: not applicable
ND	ND: Not detected
NR	NR: Monitoring not required, but recommended.

Important Drinking Water Definitions	
Term	Definition
MCLG	MCLG: Maximum Contaminant Level Goal: The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.
MCL	MCL: Maximum Contaminant Level: The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.
TT	TT: Treatment Technique: A required process intended to reduce the level of a contaminant in drinking water.
AL	AL: Action Level: The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.
Variances and	Variances and Exemptions: State or EPA permission not to meet an MCL or a treatment

<b>Important Drinking Water Definitions</b>	
Exemptions	technique under certain conditions.
MRDLG	MRDLG: Maximum residual disinfection level goal. The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.
MRDL	MRDL: Maximum residual disinfectant level. The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.
MNR	MNR: Monitored Not Regulated
MPL	MPL: State Assigned Maximum Permissible Level

### **Significant Deficiencies**

During a sanitary survey conducted on 2/21/2014, the Mississippi State Department of Health cited the following significant deficiency: "Failure to meet water supply demands (overloaded by serving greater than 100% capacity.)"

Corrective actions: Your water supply was changed on May 22, 2017 from the St. Andrews Water and Sewer, Inc. System 0300033 to the Jackson County Regional Supply – West 0300164 and this significant deficiency has been corrected. (Reference: MSDH Confirmation Letter: dated 7/31/2017.

For additional information please contact JCUA Water Supply at (228) 762-0119